



TYPICAL SECTION

TO BE USED WHEN THE BARRIER IS FREE STANDING (NO BACKING) AT THE TOP OF FILL SLOPES.

SEE STD. MD 648.45 FOR 34 INCH F SHAPE CONCRETE TRAFFIC BARRIER SINGLE FACE TYPE 1 WITH EARTH BACKING AT TOP OF FILL SLOPES.

SEE STD. MD 648.47 FOR 34 INCH F SHAPE CONCRETE TRAFFIC BARRIER SINGLE FACE TYPE 3 FUNCTIONING AS A RETAINING WALL AT THE BOTTOM OF CUT OR FILL SLOPES.

NOTES

1. CAST THE BARRIER AND FOOTER SEPARATELY USING FIXED FORM OR SLIP FORM CONSTRUCTION WITH CONCRETE MIX NO.6 (4500 PSI).
2. THE BARRIER FOOTER MAY BE CONSTRUCTED AFTER CONSTRUCTION OF THE PAVEMENT. IF FLEXIBLE PAVEMENT IS CONSTRUCTED BEFORE THE FOOTER, SAWCUT THE PAVEMENT TO PROVIDE A CLEAN EDGE. REMOVE FOOTER FORMS IF THE FOOTER IS CONSTRUCTED BEFORE THE PAVEMENT.
3. LAP BARS 2'-10 1/2". TIE BARS TOGETHER.
4. THE FOOTER REAR VERTICAL FACE MAY BE FORMED OR THE CONCRETE PLACED AGAINST THE VERTICAL EARTH SIDE IF APPROVED BY THE ENGINEER. NO ADDITIONAL COMPENSATION FOR ADDITIONAL CONCRETE WILL BE PAID IF CONCRETE IS PLACED AGAINST THE EARTH.
5. MAXIMUM SPACING OF CONTRACTION JOINTS IS 20 FEET. PLACE EXPANSION JOINTS IN THE BARRIER AND FOOTER AT THE END OF POUR. AT PC AND PT LOCATIONS, STRUCTURES, EXPANSION JOINTS IN ABUTTING CONCRETE AND UNDERLYING CONCRETE. LOCATIONS AS SHOWN ON THE PLANS, AND AS DIRECTED BY THE ENGINEER. AT EXPANSION JOINTS, SPACE BARRIER SECTIONS 3/4" APART AND FILL THE OPENING WITH 3/4" PREFORMED JOINT FILLER. RECESS THE FILLER 1/4" FROM THE FACE OF BARRIER.
6. COST OF THE CONCRETE FOOTER, REINFORCEMENT, AND EXCAVATION IS INCIDENTAL TO THE CONTRACT UNIT PRICE PER LINEAR FOOT FOR 34 INCH F SHAPE CONCRETE TRAFFIC BARRIER SINGLE FACE TYPE 2. FILL MATERIAL IN BACK OF THE BARRIER IS INCLUDED IN THE EMBANKMENT QUANTITY.
7. TOLERANCES IN DIMENSIONS SHOWN ARE WITHIN 1/4".
8. CONDUIT: IF REQUIRED REFER TO STD. MD 648.50 FOR LOCATION AND DETAILS.
9. WHEN BARRIER IS CONSTRUCTED USING THE SLIP FORM METHOD, DIAGONAL NO. 4 BARS ARE REQUIRED. SEE STD. MD 648.49.
10. THE CONTRACTOR MAY CONSTRUCT THE VERTICAL NO. 5 BARS AS SHOWN ON THIS STANDARD OR USE THE LAP SPLICE SHOWN ON STD. NO. MD 648.48. NO ADDITIONAL COMPENSATION WILL BE MADE FOR WHICHEVER OPTION IS CONSTRUCTED.

TL-3

SPECIFICATION 604	CATEGORY CODE ITEMS
APPROVED	<i>Charles P. ...</i> DIRECTOR - OFFICE OF HIGHWAY DEVELOPMENT
APPROVAL SHA REVISIONS	APPROVAL FEDERAL HIGHWAY ADMINISTRATION
APPROVAL 3-1-01	APPROVAL 3-28-01
REVISED 8-12-02	REVISED
REVISED 6-27-23	REVISED 6-21-23
REVISED	REVISED

MOT MARYLAND DEPARTMENT OF TRANSPORTATION
STATE HIGHWAY ADMINISTRATION

STANDARDS FOR HIGHWAYS AND INCIDENTAL STRUCTURES
34 INCH F SHAPE
CONCRETE TRAFFIC BARRIER SINGLE FACE
TYPE 2 (FREE STANDING IN FILL)

STANDARD NO. MD 648.46