



PLAN

NOTES

1. WHERE THE CONTINUOUS WIDTH FOR TRAVEL IS LESS THAN 60", SIDEWALK PASSING ZONES SHALL BE PROVIDED AT AN INTERVAL NOT TO EXCEED 200'. USE OF ENTRANCES AND LEADER WALKS AS PASSING ZONES IS ACCEPTABLE PROVIDED THAT THE GEOMETRY MEETS THE REQUIREMENTS OF THIS STANDARD.
2. SIDEWALK PASSING ZONES SHALL BE LOCATED AS INDICATED ON DRAWINGS, HOWEVER EXISTING LIGHT POLES, FIRE HYDRANTS, DROP INLETS, ETC. MAY AFFECT PLACEMENT.
3. SIDEWALK TRANSVERSE SLOPE SHALL BE MAINTAINED ACROSS THE ENTIRE WIDTH OF THE PASSING ZONE (48:1 MAX.).

SPECIFICATION 603	CATEGORY CODE ITEMS	Maryland Department of Transportation STATE HIGHWAY ADMINISTRATION STANDARDS FOR HIGHWAYS AND INCIDENTAL STRUCTURES
APPROVED	 DIRECTOR - OFFICE OF HIGHWAY DEVELOPMENT	
 SHA State Highway Administration	APPROVAL • SHA REVISIONS	SIDEWALK PASSING ZONES
	APPROVAL 2-10-04	APPROVAL 3-31-04
	REVISED	REVISED
	REVISED	REVISED
STANDARD NO. MD 655.02		