



**NOTES:**

1. CHAMFER ALL EXPOSED CONCRETE EDGES 1".
2. LIGHTING CONTROL CABINET FOUNDATION REQUIRES 1.5 CY CONCRETE.
3. FOUNDATION SHALL NOT BE INSTALLED IN DRAINAGE DITCH.

SPECIFICATION <b>801,816</b>	CATEGORY CODE ITEMS
APPROVED	 DIRECTOR - OFFICE OF TRAFFIC AND SAFETY
	APPROVAL • SHA REVISIONS
	APPROVAL • FEDERAL HIGHWAY ADMINISTRATION
	APPROVAL 7-1-94
	REVISIONS 5-17-07
	REVISIONS 5-2-07

**Maryland Department of Transportation**  
**STATE HIGHWAY ADMINISTRATION**  
 STANDARDS FOR HIGHWAYS AND INCIDENTAL STRUCTURES

**FOUNDATION DETAILS FOR BASE-MOUNTED  
 LIGHTING CONTROL CABINET**

**STANDARD NO.**

**MD 801.03**