




NOTES:

1. ALL METALLIC CONDUIT ENDS, FRAME, AND COVER SHALL BE BONDED WITH OTHER CONDUIT ENDS USING BONDING BUSHINGS AND NO. 6 AWG STRANDED COPPER WIRE.
2. HANDHOLE FRAME AND COVER SHALL BE GALVANIZED PER A123 AND A153, RESPECTIVELY.



HANDLE ASSEMBLY DETAIL



DETAIL D

SPECIFICATION 811	CATEGORY CODE ITEMS										
APPROVED <i>Cedric W. S.</i> DIRECTOR - OFFICE OF TRAFFIC AND SAFETY											
SHA State Highway Administration	<table> <tr> <td>APPROVAL • SHA REVISIONS</td><td>APPROVAL • FEDERAL HIGHWAY ADMINISTRATION</td></tr> <tr> <td>APPROVAL 5-15-17</td><td>APPROVAL 3-24-17</td></tr> <tr> <td>REVISED</td><td>REVISED</td></tr> <tr> <td>REVISED</td><td>REVISED</td></tr> <tr> <td>REVISED</td><td>REVISED</td></tr> </table>	APPROVAL • SHA REVISIONS	APPROVAL • FEDERAL HIGHWAY ADMINISTRATION	APPROVAL 5-15-17	APPROVAL 3-24-17	REVISED	REVISED	REVISED	REVISED	REVISED	REVISED
APPROVAL • SHA REVISIONS	APPROVAL • FEDERAL HIGHWAY ADMINISTRATION										
APPROVAL 5-15-17	APPROVAL 3-24-17										
REVISED	REVISED										
REVISED	REVISED										
REVISED	REVISED										

Maryland Department of Transportation
STATE HIGHWAY ADMINISTRATION
 STANDARDS FOR HIGHWAYS AND INCIDENTAL STRUCTURES

OVERSIZED ELECTRICAL HANDHOLE FRAME AND COVER

STANDARD NO.

MD 811.06