



NOTES:

1. EACH PHASE AND ASSOCIATED NEUTRAL CABLE SHALL BE IN AN INDEPENDENT DUCT CABLE.
2. ALL DUCT CABLES NOT SERVICING THE POLE BASE SHALL NOT ENTER THE POLE BASE AND SHALL BYPASS THE FOUNDATION.
3. ALL CONNECTOR KITS SHALL BE WITHIN 2" OF FOUNDATION.

SPECIFICATION 810	CATEGORY CODE ITEMS
APPROVED  DIRECTOR - OFFICE OF TRAFFIC AND SAFETY	
	APPROVAL • SHA REVISIONS
	APPROVAL • FEDERAL HIGHWAY ADMINISTRATION
	APPROVAL 7-1-94
	REVISION 5-17-07
	REVISION

Maryland Department of Transportation
STATE HIGHWAY ADMINISTRATION
 STANDARDS FOR HIGHWAYS AND INCIDENTAL STRUCTURES
ROADWAY LIGHTING
277/480 VOLT SYSTEM
277 VOLT POLE CONNECTIONS
STANDARD NO. MD 810.04