



NOTES:

1. WIRES FOR EACH CIRCUIT SHALL BE IN AN INDEPENDENT DUCT CABLE.
2. ALL DUCT CABLES NOT SERVICING THE POLE BASE SHALL NOT ENTER THE POLE BASE AND SHALL BYPASS THE FOUNDATION.
3. ALL CONNECTOR KITS SHALL BE WITHIN 2" OF FOUNDATION.

SPECIFICATION 810	CATEGORY CODE ITEMS	
APPROVED	 DIRECTOR - OFFICE OF TRAFFIC AND SAFETY	
	APPROVAL • SHA REVISIONS	APPROVAL • FEDERAL HIGHWAY ADMINISTRATION
	APPROVAL 7-1-94	APPROVAL 7-1-94
	REVISED 5-17-07	REVISED 5-2-07
	REVISED	REVISED
	REVISED	REVISED

Maryland Department of Transportation
STATE HIGHWAY ADMINISTRATION
 STANDARDS FOR HIGHWAYS AND INCIDENTAL STRUCTURES
ROADWAY LIGHTING
120/240 VOLT SYSTEM
240 VOLT POLE CONNECTIONS
STANDARD NO. MD 810.05